



1391

DECLARATION OF PERFORMANCE (DoP)

issued acc. to attachment Annex III Regulation (EU) No 305/2011
of the EUROPEAN PARLIAMENT AND OF THE COUNCIL of 21 February 2014
No.:DoP/VL-F/003/2016

1. Identification code

Unique identification code of the product-type:

2. Intended use/es:

Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

3. Manufacturer:

Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

4. Authorised representative:

Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

5. Certification system:

System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

6.a

Harmonised standard:

In case of the declaration of performance concerning a construction product covered by a harmonised standard:

Notified body:

In case of the declaration of performance concerning a construction product covered by a harmonised standard:

VL-F single compartment smoke extraction ducts E600 120 (v_e, h_o) S1500 single

The smoke extraction ducts are part of the smoke extraction and fire protect system. The function of the smoke extraction duct is to prevent the transmission of smoke and combustion products from the fire zone. AEROPRODUKT Zrt. produce only single compartment smoke extraction duct systems. The single compartment means that the smoke extraction ducts do not pass through into other fire compartments.

AEROPRODUKT Zrt.

Csongrád

Szegedi út 1.

H-6640

Tel: +36/63/481-143; Fax: +36/63/481-136

www.aeroproduct.hu

Not relevant

Annex V. System 1.2;

EU REGULATION No. 305/2011 of EUROPEAN PARLIAMNT AND THE COUNCIL of
09 March 201

produced according to MSZ EN 12101-7:2011

qualified according to MSZ EN 1366-9:2008

classified according to MSZ EN 13501-4:2007+A1

PAVUS, a.s.

Notified Body No. 1391

Prosecká 412/74, 190 00 Praha 9 - Prosek

Decision No. 27/2013-CPR of 13 th December 2013

Tel.: +420 286 019 587 Fax: +420 286 019 590 E-mail: mail@pavus.cz

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No.: 1391-CPR-2015/0245



1391

DECLARATION OF PERFORMANCE (DoP)

issued acc. to attachment Annex III Regulation (EU) No 305/2011
of the EUROPEAN PARLIAMENT AND OF THE COUNCIL of 21 February 2014
No.:DoP/VL-F/003/2016

7. Declared Performance:

Essential characteristics	Requirement clauses in EN 12101-8	Harmonised technical specification	Performance
integrity	4.1.2 a) – 4.4.1	E ₆₀₀	conforms
insulation			
smoke leakage	4.1.2 b) – 4.4.1	E _{600S}	conforms
mechanical stability (under E)	4.1.2 c)	-	conforms
maintenance of the cross section (under E)	4.1.2 d)	-	conforms

The VL-F smoke extraction duct system for single compartment is CE marked and tested in two hours at a temperature of 600 °C in horizontal and vertical position at different pressure.

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not relevant

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Csongrád, 23.03.2016

Mr. Zsolt PUSZTAI - Chief Executive Officer

.....
Zsolt PUSZTAI
Chief Executive Officer

The Declaration of Performance contains two numbered pages.